



ACE Filtration

CLEAN AIR FOR ALL

TECHNICAL DATA SHEET: AF128

ACE FIRE TESTED DUCT ACCESS DOOR

Construction

- Door:** Manufactured from 0.8mm galvanised sheet steel, and of 25mm thick double skin construction, incorporating Insulfrax LTX 128kg/m³ insulation. Two handles fitted to each door.
- Frame:** Folded 0.8mm galvanised steel Z section with castellated edge tabs for folding over and securing to the duct.
- Fixings:** Galvanised half turn cams riveted to door, with galvanised keeper brackets fitted to frame.
- Gasket:** One joint, 12mm x 5mm thick fire rated gasket fitted to inside of door. Frame gasketed with same, on under side, to provide positive seal between frame and ductwork.

THE DOOR HAS ACHIEVED THE TEMPERATURE AND PRESSURE CONDITIONS OF BS EN1363-1:2012 UTILISING THE PRINCIPLES OF BS EN 1634-1:2014

For fitting, please cut hole size 30mm under door size (e.g. 300 x 300 door, cut hole 270 x 270).

Notes: These doors are made to order, for accurate lead times please contact the Sales Office on 01474 325666.